

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

TOLI Corporation

2-10-4 Higashi-Shinbashi, Minatoku, Tokyo, Japan

For the following product(s):

Vinyl Tile:

E-CLEAN NW EX, LAY FLOORING, LAY FLOORING PITAFI, LIGHTSTONE, LIGHTWOOD, LL 50 CRNW, LL50 NW-EX, LL FREE 40 NW-EX, LL FREE 800, LL FREE EXCELLA, MS FRESH, MS PLAIN, ROYAL STONE, ROYAL WOOD

Applies only to vinyl tile product labeled "Made in Japan"

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

FloorScore®

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.0

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m³ (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-03027

Valid from: April 1, 2020 to March 31, 2021

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Vice President
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA
949.460.1134